

# Product Specification: Northern Quarries 56mm Aggregate

**PRODUCT CODE:** 0694

**SOURCE ROCK TYPE:** Basalt

**CUSTOMER:** Standard Product

**REFERENCE:** AS2758.1 – *Aggregates and Rock for Engineering Purposes, Concrete Aggregates*

Relevant Tests Carried Out On Source Rock				
Test	Method	Frequency	Requirements	Reference
Los Angeles (LA) Value	AS1141.23	VicRoads Issue	≤30	AS2758.1.9.3.3

Tests Carried Out For Product Quality Control Purposes				
Sampling Method: AS1141.3.1				
Test	Method	Frequency	Requirements	Reference
Unit Mass Density	AS1141.4	On initial introduction of product	N/A – For reference purposes only	N/A
Particle size distribution (Grading)	AS1141.11 (washed)	1 per Year	See table below	Conundrum historical data

Sieve Size AS (mm)	Limits of Grading (% Passing)	Target Grading (% Passing)
75.0	100	100
53.0	85 – 100	93
37.5	20 – 80	50
26.5	10 – 50	20
19.0	0 – 20	2
13.2	0 – 10	1
0.075	0 – 3	1

